

PUBLIC NOTICE

Department of Environmental Protection
Wastewater Management Program
Mail Station # 3545
2600 Blair Stone Road
Tallahassee, Florida 32399-2400
850-245-8664

NOTICE OF REQUEST FOR APPROVAL OF A PRETREATMENT PROGRAM MODIFICATION

In accordance with the provisions of Chapter 62-625, Florida Administrative Code (F.A.C.), the Black Ford Water Reclamation Facility has developed and submitted for approval by the Florida Department of Environmental Protection (DEP), a pretreatment program modification for its wastewater facility (WWF), consisting of revisions to JEA's Local Limits. DEP has made a preliminary determination that this pretreatment program modification meets the requirements of Rule 62-625.540, F.A.C. The requirements found in those rules are designed to assure the pretreatment program will: (a) prevent the introduction of pollutants into WWFs which will interfere with their operation, including the use or disposal of residuals; (b) prevent the introduction of pollutants into WWFs which will pass through the treatment works or be otherwise incompatible; and (c) improve opportunities to recycle and reclaim municipal and industrial wastewaters and residuals.

JEA's proposed pretreatment program approval submission is available for public inspection online at:

[https://depedms.dep.state.fl.us:443/Oculus/servlet/shell?command=getEntity&\[guid=38.1101849.1\]&\[profile=Permitting_Authorization\]](https://depedms.dep.state.fl.us:443/Oculus/servlet/shell?command=getEntity&[guid=38.1101849.1]&[profile=Permitting_Authorization])

[https://depedms.dep.state.fl.us:443/Oculus/servlet/shell?command=getEntity&\[guid=38.1105877.1\]&\[profile=Permitting_Authorization\]](https://depedms.dep.state.fl.us:443/Oculus/servlet/shell?command=getEntity&[guid=38.1105877.1]&[profile=Permitting_Authorization])

[https://depedms.dep.state.fl.us:443/Oculus/servlet/shell?command=getEntity&\[guid=38.1126416.1\]&\[profile=Permitting_Authorization\]](https://depedms.dep.state.fl.us:443/Oculus/servlet/shell?command=getEntity&[guid=38.1126416.1]&[profile=Permitting_Authorization])

[https://depedms.dep.state.fl.us:443/Oculus/servlet/shell?command=getEntity&\[guid=38.1266528.1\]&\[profile=Permitting_Authorization\]](https://depedms.dep.state.fl.us:443/Oculus/servlet/shell?command=getEntity&[guid=38.1266528.1]&[profile=Permitting_Authorization])

[https://depedms.dep.state.fl.us:443/Oculus/servlet/shell?command=getEntity&\[guid=38.1299390.1\]&\[profile=Permitting_Authorization\]](https://depedms.dep.state.fl.us:443/Oculus/servlet/shell?command=getEntity&[guid=38.1299390.1]&[profile=Permitting_Authorization])

Interested persons may submit written comments on the submission. All written comments submitted in a timely manner will be considered by DEP in the decision on whether to approve the submission. In accordance with paragraph 62-625.510(2)(c),

F.A.C., this public notice comment period will end thirty (30) days from the date of publication.

Any interested person may request a public hearing concerning this proposed pretreatment program. Such a public hearing is for informational purposes only. The request for public hearing must be filed with the Department within 30 days of the publication of this notice. Persons requesting a public hearing must state their interest in the matter and state reasons why such a hearing is warranted. A public hearing will be held if there is significant public interest.

Send comments or requests for public hearing to the attention of Alex Weeks, at the address at the top of this notice or by email to alexander.c.weeks@floridadep.gov.

Attachment A

	JEA MAXIMUM ALLOWABLE DISCHARGE LIMITS					v.4.15.24 for Mo (proposed)
POLLUTANTS	BUCKMAN ST WRF	DISTRICT II WRF	SOUTHWEST WRF	ARLINGTON EAST WRF	MANDARIN WRF	BLACKS FORD WRF
Cadmium (mg/L)	1.20	1.20	1.20	1.20	1.20	1.20
Chromium (mg/L)	10.00	10.00	10.00	10.00	10.00	10.00
Copper (mg/L)	3.38	0.82 (1)	none	3.38	3.38	3.38
Cyanide (mg/L)	3.38	3.38	3.38	3.38	3.38	3.38
Lead (mg/L)	1.40	0.70	1.90	1.17	1.90	1.90
Mercury (mg/L)	0.006 ⁽¹⁾	0.006 ⁽¹⁾	0.006 ⁽¹⁾	0.006 ⁽¹⁾	0.006 ⁽¹⁾	0.006 ⁽¹⁾
Molybdenum (mg/L)	2.66 ⁽¹⁾	0.741 lb/day ^(1/2)	none	none	none	none
Nickel (mg/L)	3.98 ⁽¹⁾	3.98	3.98	3.98	3.98	3.98
Silver (mg/L)	0.43	0.43	0.43	0.43	0.43	0.43
Ultraviolet Transmittance (minimum %)	30 ⁽³⁾	30 ⁽³⁾	30 ⁽³⁾	30 ⁽³⁾	30 ⁽³⁾	30 ⁽³⁾
Zinc (mg/L)	2.61	2.61	2.61	2.61	2.61	2.61
⁽¹⁾ Limits for contributory users only. Industrial User will be notified by JEA regarding its status as a contributory user.						
⁽²⁾ Limitations applied in IU permits as determined by JEA.						
⁽³⁾ Limit applies only to leachate-bearing waste streams.						